

Emission Summary

Permit Number: 070848P

Source Status: New ☐ Modification ☐ Expansion ☐ Relocation ☐ **Permit Status:** New ☒ Renewal ☐

PSD ☐ NSPS ☐ NESHAPs ☐ **Previous Permit Number:** Construction _____ Operating _____.

	Pounds/Hour			Tons/Year				Date of Data	*	Applicable Standard 1200-03-
	Actual	Potential	Allowable	Actual	Potential	Allowable	Net Change			
TSP			4.74			1.19		06/17/2015	3	06-.02(2)
CO			6.72			1.68		06/17/2015	3	07-.07(2)
NO _x			25.28			6.32		06/17/2015	3	07-.07(2)
SO ₂			0.012			0.003		06/17/2015	3	14-.03(5)
VOC			0.649			0.162		06/17/2015	3	07-.07(2)

*-Source of data: Application dated 06/17/2015

- ⁽¹⁾ The permittee has asked that allowable emissions be based on 500 hours.
⁽²⁾ The permittee has asked that the allowable emissions be based on AP-42, Chapter 3, Table 3.4-1.
⁽³⁾ Based on the manufacture date of 2004, this emergency generator is considered an existing source and it is not subject to 40 CFR 63, Subpart ZZZZ or 40 CFR 60, Subpart IIII.

PERMITTING PROGRAM: AY DATE: October 14, 2015